

Paramount Water
Hexavalent Chromium Testing-UCMR Sites
December, 2016

Weck Lab Samples (City/WRD)

Test Date	Average	Range	Minimum Reporting Level	Major Sources in Drinking Water
12/20/2016	.09 ug/l	.02 - .20	.03 ug/l	Naturally-occurring element; used in making steel and other alloys; chromium-3 or -6 forms are used for chrome plating, dyes, and pigments, leather tanning and wood preservation.

State of California-Department of Public Health (State Water Quality Control Board-Division of Drinking Water)

Test Date	Average	Range	Minimum Reporting Level	Major Sources in Drinking Water
12/20/2016	<1 ug/l	NA	.03 ug/l	Naturally-occurring element; used in making steel and other alloys; chromium-3 or -6 forms are used for chrome plating, dyes, and pigments, leather tanning and wood preservation.