

Paramount Water
Hexavalent Chromium Testing-UCMR Sites
(December /2017)

Sample Date	Average	Range	Minimum Reporting Level	Major Sources in Drinking Water
December 4, 2017	0.118	0.035 – 0.34	.03 ug/l	Naturally-occurring element; used in making steel and other alloys; chromium-3 or -6 forms are used for chrome plating, dyes, and pigments, leather tanning and wood preservation.