

Paramount Water
Hexavalent Chromium Testing-UCMR Sites
(July 2017)

Sample Date	Average	Range	Minimum Reporting Level	Major Sources in Drinking Water
July 3, 2017	0.105	ND - .42	.03 ug/l	Naturally-occurring element; used in making steel and other alloys; chromium-3 or -6 forms are used for chrome plating, dyes, and pigments, leather tanning and wood preservation.