

Paramount Water
Hexavalent Chromium Testing-UCMR Sites
March, 2017

Sample Date	Average	Range	Minimum Reporting Level	Major Sources in Drinking Water
3/6/17	0.279 ug/l	0.05 – 1.4	.03 ug/l	Naturally-occurring element; used in making steel and other alloys; chromium-3 or -6 forms are used for chrome plating, dyes, and pigments, leather tanning and wood preservation.