



DIRECTORS
ROB KATHERMAN, PRESIDENT
JOHN D. S. ALLEN, VICE PRESIDENT
SERGIO CALDERON, SECRETARY
ALBERT ROBLES, TREASURER
WILLARD H. MURRAY, JR., DIRECTOR

ROBB WHITAKER, P.E., GENERAL MANAGER

January 11, 2017

Mr. Christopher Cash
City of Paramount
16400 Colorado Avenue
Paramount, CA 90723

Regarding: UCMR 3 Consumer Confidence Reporting (CCR) 2015

The City of Paramount contracts with the Water Replenishment District of Southern California (WRD) to test water samples, compile water quality data and assist in development of the Consumer Confidence Report for the City's water supply. Through an audit that was conducted of the City's most recent 2015 CCR, we concluded that there were several results that the lab had incorrectly reported and we have revised the report to show the correct data.

The 1996 amendment to the Safe Drinking Water Act (SDWA) requires that once every five years, the U.S. Environmental Protection Agency (EPA) issue a new list of no more than 30 unregulated contaminants to be monitored by public water systems (PWSs). The Unregulated Contaminant Monitoring Rule (UCMR) provides EPA and other interested parties with scientifically valid data on the occurrence of contaminants in drinking water. . UCMR 3 monitoring took place from 2013-2015 and included monitoring for 28 chemicals and two viruses. By definition of the UCMR 3 program, there are no established maximum contaminant levels for the constituents tested under this program.

The City of Paramount was required to sample from 2013 to 2014 for UCMR 3 and the data was reported in the 2015 Consumer Confidence Report (CCR). Samples were taken from the wells, distribution system connections, and imported water connections used as a water supply by the City of Paramount. UCMR 3 sampling occurred for the City of Paramount on the following dates:

- January 29, 2013
- April 29, 2013
- May 14, 2013
- July 31, 2013
- October 31, 2013
- January 30, 2014
- April 28, 2014

For the CCR Report, all data was combined to determine the overall average and range for each chemical as required by the State of California. In November 2016, it was discovered that results



DIRECTORS
ROB KATHERMAN, PRESIDENT
JOHN D. S. ALLEN, VICE PRESIDENT
SERGIO CALDERON, SECRETARY
ALBERT ROBLES, TREASURER
WILLARD H. MURRAY, JR., DIRECTOR

ROBB WHITAKER, P.E., GENERAL MANAGER

for a Chlorate sample from the July 2013 sampling event was incorrectly reported in the CCR as a Hexavalent Chromium reading. Once it was determined that the sample results for the Hexavalent Chromium was reported incorrectly, the District audited all UCMR 3 data received from the contracted laboratory. This review by WRD resulted in a revised CCR for the City of Paramount that included the correction of the Hexavalent Chromium and Chlorate results, and also corrected the reported results for Molybdenum, Strontium, and Vanadium as well as the addition of sampling results for 1,1-Dichlorethane. We notified you of the correction to the Hexavalent Chromium category in a previous letter. We are now notifying you of the corrections that were also made to the other four (4) categories mentioned above. The corrected data has been reported to the State Water Resources Control Board, Division of Drinking Water who has accepted the results.

In the end, the water supply for the City of Paramount tested as part of the 2015 CCR, which includes the audited and verified data from July 2013 UCMR 3 requirement, meets or exceeds all established and regulated safe drinking water standards.

Sincerely,

A handwritten signature in blue ink, appearing to read "Robb Whitaker".

Robb Whitaker, P.E.
General Manager
Water Replenishment District of Southern California



1
2
3
4
5
6
7
8
9
10
11
12
13

Laboratory Report

Client: TestAmerica Report: 300896
Attn: Kathleen Robb Priority: Standard Written
17461 Derian Suite 100
Irvine, CA 92614 Status: Final
Copies to: None Lab ID Code: IN00035
PWS Facility Name: Well 13 PWS ID: CA1910105
Sampling Point Name: Well 13 Disinfection Station Sampling Point ID: 1910105022W13D
Sampling Point Type: EP Sample Event Code: SE2

Sample Information					
UL ID #	Client ID	Method	Collected Date / Time	Collected By:	Received Date / Time
2869230	Well 13 Disinfection Station	522	07/31/13 10:30	Client	08/02/13 10:30
2869231	Well 13 Disinfection Station	200.8	07/31/13 10:30	Client	08/02/13 10:30
2869233	Well 13 Disinfection Station	537	07/31/13 10:30	Client	08/02/13 10:30
2869235	Well 13 Disinfection Station	300.1	07/31/13 10:30	Client	08/02/13 10:30
2869237	Well 13 Disinfection Station	524.3	07/31/13 10:30	Client	08/02/13 10:30
2869232	FTB-7/15/13	200.8	07/31/13 10:30	UL	08/02/13 10:30

Report Summary

Note: Per the US EPA, Field Blank data are not uploaded to SDWARs. The data is however to be maintained on site at the laboratory performing the analysis.

Detailed quantitative results are presented on the following pages. The results presented relate only to the samples provided for analysis.

We appreciate the opportunity to provide you with this analysis. If you have any questions concerning this report, please do not hesitate to call Kelly Trott at (574) 233-4777.

Note: This report may not be reproduced, except in full, without written approval from UL.

Authorized Signature

Title

Date

Client Name: TestAmerica
Report #: 300896

Page 1 of 3

UL LLC
110 S. Hill St., South Bend, IN 46617-2702 USA
T: 800.332.4345 / F: 574.233.8207 / W: UL.com

Sampling Point Name: Well 13 Disinfection Station

PWS ID: CA1910105

UCMR Assessment Monitoring								
Analyte ID #	Analyte	Method	MRL†	Result	Units	Preparation Date	Analyzed Date	UL ID #
1020	Chromium	200.8	0.2	< 0.2	ug/L	08/05/13 11:30	08/06/13 18:48	2869231
1081	Cobalt	200.8	1.0	< 1.0	ug/L	08/05/13 11:30	08/06/13 18:48	2869231
1084	Molybdenum	200.8	1.0	3.8	ug/L	08/05/13 11:30	08/06/13 18:48	2869231
1051	Strontium	200.8	0.3	430	ug/L	08/05/13 11:30	08/06/13 18:48	2869231
1088	Vanadium	200.8	0.2	0.4	ug/L	08/05/13 11:30	08/06/13 18:48	2869231
1007	Chlorate	300.1	20	460	ug/L	---	08/16/13 21:26	2869235
2049	1,4-Dioxane	522	0.07	< 0.07	ug/L	08/07/13 07:30	08/08/13 19:59	2869230
2430	Bromochloromethane	524.3	0.06	< 0.06	ug/L	---	08/06/13 11:42	2869237
2214	Bromomethane	524.3	0.2	< 0.2	ug/L	---	08/06/13 11:42	2869237
2486	1,3-Butadiene	524.3	0.1	< 0.1	ug/L	---	08/06/13 11:42	2869237
2487	Chlorodifluoromethane	524.3	0.08	< 0.08	ug/L	---	08/06/13 11:42	2869237
2210	Chloromethane	524.3	0.2	< 0.2	ug/L	---	08/06/13 11:42	2869237
2978	1,1-Dichloroethane	524.3	0.03	< 0.03	ug/L	---	08/06/13 11:42	2869237
2414	1,2,3-Trichloropropane	524.3	0.03	< 0.03	ug/L	---	08/06/13 11:42	2869237
2801	Perfluorobutanesulfonic acid (PFBS)	537	0.09	< 0.09	ug/L	08/06/13 07:40	08/09/13 02:01	2869233
2802	Perfluoroheptanoic acid (PFHpA)	537	0.01	< 0.01	ug/L	08/06/13 07:40	08/09/13 02:01	2869233
2803	Perfluorohexanesulfonic acid (PFHxS)	537	0.03	< 0.03	ug/L	08/06/13 07:40	08/09/13 02:01	2869233
2804	Perfluorononanoic acid (PFNA)	537	0.02	< 0.02	ug/L	08/06/13 07:40	08/09/13 02:01	2869233
2805	Perfluorooctane sulfonate (PFOS)	537	0.04	< 0.04	ug/L	08/06/13 07:40	08/09/13 02:01	2869233
2806	Perfluorooctanoic acid (PFOA)	537	0.02	< 0.02	ug/L	08/06/13 07:40	08/09/13 02:01	2869233

† UL has demonstrated it can achieve these report limits in reagent water, but can not document them in all sample matrices.

Sampling Point Name: FTB

PWS ID: CA1910105

UCMR Assessment Monitoring								
Analyte ID #	Analyte	Method	MRL†	Result	Units	Preparation Date	Analyzed Date	UL ID #
1020	Chromium	200.8	0.2	< 0.2	ug/L	08/05/13 11:30	08/06/13 20:40	2869232
1081	Cobalt	200.8	1.0	< 1.0	ug/L	08/05/13 11:30	08/06/13 20:40	2869232
1084	Molybdenum	200.8	1.0	< 1.0	ug/L	08/05/13 11:30	08/06/13 20:40	2869232
1051	Strontium	200.8	0.3	< 0.3	ug/L	08/05/13 11:30	08/06/13 20:40	2869232
1088	Vanadium	200.8	0.2	< 0.2	ug/L	08/05/13 11:30	08/06/13 20:40	2869232

† UL has demonstrated it can achieve these report limits in reagent water, but can not document them in all sample matrices.

The City's Water Consumer Confidence Report has been updated. The Water Replenishment District (WRD), the independent entity that conducts testing of the City of Paramount's water supply, found an error in the results of their latest testing. That change is reflected in the chart on the last page.

CITY OF PARAMOUNT

2015 CONSUMER CONFIDENCE REPORT

Since 1991, California water utilities have been providing information on water served to its consumers. This report is a snapshot of the tap water quality that we provided last year. Included are details about where your water comes from, how it is tested, what is in it, and how it compares with state and federal limits. We strive to keep you informed about the quality of your water, and to provide a reliable and economic supply that meets all regulatory requirements.



Metropolitan Water District of Southern California's (MWD) surface water from both the Colorado River and the State Water Project in northern California. These water sources supply our service area shown on the adjacent map. The quality of our groundwater and MWD's surface water supplies is presented in this report.

How is My Drinking Water Tested?

Your drinking water is tested regularly for unsafe levels of chemicals, radioactivity and bacteria at the source and in the distribution system. We test weekly, monthly, quarterly, annually or less often depending on the substance. State and federal laws allow us to test some substances less than once per year because their levels do not change frequently. All water quality tests are conducted by specially trained technicians in state-certified laboratories.

What Are Drinking Water Standards?

The U.S Environmental Protection Agency (USEPA) limits the amount of certain substances allowed in tap water. In California, the State Water Resources Control Board (State Board) regulates tap water quality by enforcing limits that are at least as stringent as the Federal EPA's. Historically, California limits are more stringent than the Federal ones.

There are two types of these limits, known as standards. Primary standards protect you from substances that could potentially affect your health. Secondary standards regulate substances that affect the aesthetic qualities of

water. Regulations set a Maximum Contaminant Level (MCL) for each of the primary and secondary standards. The MCL is the highest level of a substance that is allowed in your drinking water.

Public Health Goals (PHGs) are set by the California Environmental Protection Agency. PHGs provide more information on the quality of drinking water to customers, and are similar to their federal counterparts, Maximum Contaminant Level Goals (MCLGs). PHGs and MCLGs are advisory levels that are non-enforceable. Both PHGs and MCLGs are concentrations of a substance below which there are no known or expected health risks.

How Do I Read the Water Quality Table?

Although we test for over 100 substances, regulations require us to report only those found in your water. The first column of the water quality table lists substances detected in your water. The next columns list the average concentration and range of concentrations found in your drinking water. Following are columns that list the MCL and PHG or MCLG, if appropriate. The last column describes the likely sources of these substances in drinking water.

To review the quality of your drinking water, compare the highest concentration and the MCL. Check for substances greater than the MCL. Exceedence of a primary MCL does not usually constitute an immediate health threat. Rather, it requires testing the source water more frequently for a short duration. If test results show that the water continues to exceed the MCL, the water must be treated to remove the substance, or the source must be removed from service.

Why Do I See So Much Coverage in the News About the Quality Of Tap Water?

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, including viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife;
- Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming;
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses;

- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems;
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resources Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The State Board regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791). You can also get more information on tap water by logging on to these helpful web sites:

- <http://water.epa.gov/drink/standards/hascience.cfm>
(Federal EPA's web site)
- www.waterboards.ca.gov/drinking_water/programs/index.shtml
(State Board web site)

If present, elevated levels of lead can cause serious health problem, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with services lines and home plumbing. The City of Paramount is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Should I Take Additional Precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The USEPA/Centers for Disease Control guidelines on appropriate means to lessen the risk of

infection of *Cryptosporidium* and other microbial contaminants are available from the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Source Water Assessment

MWD completed an assessment of its Colorado River and State Water Project supplies in 2002. Colorado River supplies are considered most vulnerable to recreation, urban/storm water runoff, increasing urbanization in the watershed, and wastewater. State Water Project supplies are considered most vulnerable to urban/storm water runoff, wildlife, agriculture, recreation and wastewater. A copy of the assessment can be obtained by contacting MWD at (213) 217-6850.

The City of Paramount conducted an assessment of its groundwater supplies in 2003. Groundwater supplies are considered most vulnerable to chemical/petroleum processing/storage, metal plating/finishing/fabricating, dry cleaners, automobile gas stations, automobile body shops, automobile repair shops, junk/scrap/salvage yards, and plastics/synthetics producers. A copy of the approved assessment may be obtained by contacting the Paramount Public Works Department at (562) 220-2020.

How Can I Participate in Decisions On Water Issues That Affect Me?

The public is welcome to attend Public Works Commission meetings located at Paramount City Hall, 16400 Colorado Avenue, Paramount, CA 90723. Meetings are held on the 1st Thursday of each month at 6:00 pm.

How Do I Contact My Water Agency If I Have Any Questions About Water Quality?

If you have specific questions about your tap water quality, please contact Sarah Ho, Assistant Public Works Director at (562) 220-2020.

Some Helpful Water Conservation Tips

- Fix leaky faucets in your home – save up to 20 gallons every day for every leak stopped
- Save between 15 and 50 gallons each time by only washing full loads of laundry
- Adjust your sprinklers so that water lands on your lawn/garden, not the sidewalk/driveway – save 500 gallons per month
- Use organic mulch around plants to reduce evaporation – save hundreds of gallons a year
- Use a water-efficient showerhead. They're inexpensive, easy to install, and can save you up to 750 gallons a month.

Visit us at www.paramountcity.com

CITY OF PARAMOUNT 2015 CONSUMER CONFIDENCE REPORT

The State allows monitoring for some contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Some of the data, though representative, are more than one year old

PRIMARY STANDARDS MONITORED AT THE SOURCE-MANDATED FOR PUBLIC HEALTH

ORGANIC CHEMICALS (µg/l)	GROUNDWATER			MWD'S SURFACE WATER			MAJOR SOURCES IN DRINKING WATER		
	AVERAGE	RANGE	AVERAGE	RANGE	PRIMARY MCL	MCLG or PHG			
(a)	(a)	(a)	(a)	(a)	(a)	(a)			
INORGANICS									
Aluminum (mg/l)	ND	10.4	3.7 - 20.9	2.1	0.08 - 0.2	1	0.6 (c)	Erosion of natural deposits; residue from surface water treatment processes	
Arsenic (µg/l) (k)	0.15	0.14 - 0.16	0.12	0.12	1	2 (c)	Erosion of natural deposits; glass/electronics production wastes; runoff.		
Barium (mg/l)	0.31	0.26 - 0.38	0.70	0.6 - 1.2	2.0	1 (c)	Oil drilling waste and metal refinery discharge; erosion of natural deposits		
Fluoride (mg/l) (l)	0.2	ND - 2.3	ND	ND	10	10 (c)	Erosion of natural deposits; water additive that promotes strong teeth		
Nitrate (mg/l as N)	0.6	ND - 1.8	3	2.0 - 3.0	20 (e)	0.5 (c)	Runoff and leaching from fertilizer use/septic tanks/sewage; natural erosion		
RADIOLOGICAL - (pCi/l) (Sampled from 2013 to 2015) (b)									
Gross Alpha	1.72	ND - 3.6	ND	ND - 4.0	15 (e)	0	Erosion of natural deposits		
Gross Beta	NA	NA	5.0	4.0 - 6.0	50 (e)	0	Decay of natural and man-made deposits		
Radium 226	0.22	ND - 0.55	ND	ND	5 (d)	0.05	Erosion of natural deposits		
Radium 228	0.08	0.03 - 0.17	ND	ND	0.019	0.019	Human and animal fecal waste		
Uranium	0.6	ND - 1.8	3	2.0 - 3.0	20 (e)	0.5 (c)	Erosion of natural deposits		

PRIMARY STANDARDS MONITORED IN THE DISTRIBUTION SYSTEM - MANDATED FOR PUBLIC HEALTH

MICROBIALS	DISTRIBUTION SYSTEM			PRIMARY MCL			MCLG or PHG		
	AVERAGE % POSITIVE	RANGE % POSITIVE	0% - 1.1%	MCL	5%	0%	Naturally present in the environment		
Total Coliform and E.Coli Bacteria	0.0%	0.0%	ND	80	-	-	Human and animal fecal waste		
No. of Acute Violations	0	0	0	-	-	-			
MICROBIALS	AVERAGE	DISTRIBUTION SYSTEM RANGE		PRIMARY MCL	MCLG or PHG				
Turbidity (NTU)	0.2	0.01 - 0.86	TT	-	-	Soil runoff. Turbidity is a measure of the cloudiness of water. We monitor it because it is a good indicator of water quality.			

DISINFECTION BY-PRODUCTS AND DISINFECTANT RESIDUALS (f)	DISTRIBUTION SYSTEM			PRIMARY MCL			MCLG or PHG		
	AVERAGE	RANGE	# OF SITES ABOVE THE AL	MCL	MCLG or PHG				
Total Trihalomethanes- TTHMs (µg/l)	10	3.0 - 14.0	80	-	-	By-product of drinking water chlorination			
Halogenated Acids (µg/l)	0.9	ND - 2.6	60	-	-	By-product of drinking water disinfection			
Total Chlorine Residual (mg/l)	0.8	0.36 - 1.47	4.0 (g)	4.0 (h)	-	Drinking water disinfectant added for treatment			
AT THE TAP PHYSICAL CONSTITUENTS	AVERAGE	DISTRIBUTION SYSTEM RANGE		PRIMARY MCL	MCLG or PHG				
31 sites sampled in 2013	90%ile			1.3 AL	0.17 (c)	Internal corrosion of household plumbing, erosion of natural deposits			
Copper (mg/l)	0.28 (l)	0	0	15 AL	2 (c)	Internal corrosion of household plumbing, industrial manufacturer discharges			
Lead (µg/l)	ND (i)								

SECONDARY STANDARDS MONITORED AT THE SOURCE-FOR AESTHETIC PURPOSES

Secondary Standards Monitored at the Source	GROUNDWATER			MWD'S SURFACE WATER			SECONDARY MCL		
	AVERAGE	RANGE	AVERAGE	RANGE	MCL	MCLG or PHG			
(k)	(k)	(k)	(k)	(k)					
AGGRESSIVENESS INDEX (CORROSIVITY)									
Aggressiveness Index (corrosivity)	12.5	12.4 - 12.5	12.5	12.5	Non-corrosive	-	Natural/industrially-influenced balance of hydrogen/carbon/oxygen in water		
Aluminum (µg/l) (j)	ND	ND	156	88.0 - 200	200	600 (c)	Erosion of natural deposits, surface water treatment process residue		
Chloride (mg/l)	23.3	13.0 - 34.0	100	98.0 - 102	500	-	Runoff/leaching from natural deposits, seawater influence		
Color (color units)	ND	ND	1	1	15	-	Naturally-occurring organic ions when in water, seawater influence		
Specific Conductance (µS/cm)	523.3	430 - 610	1040	1,030 - 1,060	1,600	-	Substances that form ions when in water, seawater influence		
Manganese (µg/l) (k)	44.9	ND - 95.0	ND	ND	50	-	Leaching from natural deposits		
Odor (threshold odor number)	1	1	2	2.0	3	-	Naturally-occurring organic materials		
Sulfate (mg/l)	52.3	23.0 - 70.0	257	252 - 261	500	-	Runoff/leaching from natural deposits, industrial wastes		
Total Dissolved Solids (mg/l)	316.7	270 - 360	660	654.0 - 665.0	1,000	-	Runoff/leaching from natural deposits		
Turbidity (NTU)	ND	ND	ND	ND	5	-	Soil runoff		

SECONDARY STANDARDS MONITORED IN THE DISTRIBUTION SYSTEM-FOR AESTHETIC PURPOSES

GENERAL	DISTRIBUTION SYSTEM	SECONDARY	MCLG or PHG
PHYSICAL CONSTITUENTS	AVERAGE	RANGE	MCL
Color (color units)	<5	<5	15
Odor (threshold odor number)	1	1	3

ADDITIONAL CHEMICALS OF INTEREST

	MWD'S SURFACE WATER		
	GROUNDWATER AVERAGE	RANGE	AVERAGE RANGE
Alkalinity (mg/l)	203.3	190 - 210	126.0 123 - 129
Boron (ug/l)	NA	NA	120.0 120.0
Calcium (mg/l)	63.0	58.1 - 72.0	78.0 77.0 - 78.0
1,4-Dioxane (ug/l)	(m)	2.4	2.2 - 2.6 NA
Magnesium (mg/l)	8.1	5.5 - 12.0	27.0 26.0 - 28.0
N-Nitrosodimethylamine (ug/l)	NA	NA	ND ND - 0.006
pH (standard unit)	8.0	7.9 - 8.1	8.1 8.1
Potassium (mg/l)	2.9	2.6 - 3.2	4.9 4.8 - 5.0
Sodium (mg/l)	36.3	28.0 - 45.0	100.0 97.0 - 102.0
Total Hardness (mg/l)	191.0	170.0 - 230.0	300.0 286.0 - 304.0
Total Organic Carbon (mg/l)	NA	NA	2.4 - 2.8

FOOTNOTES

- (a) Over 50 regulated and unregulated organic chemicals were analyzed. None were detected at or above the reporting limit in groundwater or surface water sources.
- (b) Indicates dates sampled for groundwater sources only.
- (c) California Public Health Goal (PHG). Other advisory levels listed in this column are federal Maximum Contaminant Level Goals (MCLGs).
- (d) Combined Radium 226 + Radium 228 has a Maximum Contaminant Level (MCL) of 5 pCi/L.
- (e) MCL compliance based on 4 consecutive quarters of sampling.
- (f) Running annual average used to calculate average, range, and MCL compliance.
- (g) Maximum Residual Disinfectant Level Goal (MRDLG)
- (h) Maximum Residual Disinfectant Level Goal (MRDL)
- (i) 90th percentile from the most recent sampling at selected customer taps.
- (j) Aluminum has primary and secondary standards.
- (k) While your drinking water meets the federal and state standard for arsenic, it does contain low levels of arsenic. The arsenic standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. The US Environmental Protection Agency continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems. **For this well system, the filtration treatment technique is used to remove arsenic and manganese from the water prior to distribution.** Water after treatment is in compliance and below the MCL.
- (l) Starting June 1, 2015, the fluoride levels at the MWD treatment plants were adjusted to achieve an optimal fluoride level of 0.7 ppm and a control range of 0.6 ppm to 1.2 ppm to comply with the existing State's Water Fluoridation Standards. MWD was in compliance with all provisions of the State's requirements.
- (m) The Notification Level of 1 ug/l for 1,4-Dioxane was exceeded in several wells in 2015. Some people who use water containing 1,4-dioxane in excess of the Notification Level over many years may experience liver or kidney problems and may have an increased risk of getting cancer, based on studies in laboratory animals.

ABBREVIATIONS

mg/l = milligrams per liter or parts per million (equivalent to 1 drop in 42 gallons)	NA = constituent not analyzed
ND = constituent not detected at the testing limit	NTU = nephelometric turbidity units
ng/l = nanograms per liter or parts per trillion (equivalent to 1 drop in 42,000,000 gallons)	ug/l = micrograms per liter or parts per billion (equivalent to 1 drop in 42,000 gallons)
pCi/l = picocuries per liter	SI = saturation index
uS/cm = microsiemens per centimeter	

DEFINITIONS

Maximum Contaminant Level (MCL) : The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.	Public Health Goal (PHG) : The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency.
Maximum Contaminant Level Goal (MCLG) : The level of a contaminant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.	Maximum Residual Disinfectant Level (MRDL) : The highest level of a disinfectant allowed in drinking water. Contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Maximum Residual Disinfectant Level Goal (MRDLG) : The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.	Regulatory Action Level (AL) : The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
Treatment Technique (TT) : A required process intended to reduce the level of a contaminant in drinking water.	Primary Drinking Water Standard (PDWS) : MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.
Secondary Drinking Water Standard (SDWS) : MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.	Variances and Exemptions : Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

UNREGULATED CONTAMINANT MONITORING REGULATION (UCMR 3)

The Safe Drinking Water Act requires the Environmental Protection Agency (EPA) to identify unregulated contaminants for potential regulations. Every five years, EPA identifies a list of unregulated contaminants to be monitored by the nation's water utilities over a three year period. This occurred in 2013-2015 with the third UCMR (UCMR-3). The City of Paramount has monitored for a total of 21 chemical contaminants from its wells along with a corresponding sampling from the distribution system reflecting water from each well. Once EPA has obtained this occurrence data nationally, they are required to determine if there is a meaningful opportunity for increased health protection of drinking water by regulating these contaminants. The findings from this monitoring are reported in this year's Consumer Confidence Report.

THIRD UNREGULATED CONTAMINANT MONITORING REGULATION (UCMR3)

Monitored in 2013 - 2015				MINIMUM REPORTING LEVEL	MAJOR SOURCES IN DRINKING WATER
CHEMICALS PARAMETERS	AVERAGE	RANGE			
1,1-Dichloroethane (ug/l)	ND	ND - 0.03	0.03	Halogenated alkane; used as a solvent.	
Chlorate (ug/l)	173.89	22.0 - 460.0	20 ug/l	Agricultural defoliant or desiccant; disinfection byproduct; and used in production of chlorine dioxide.	
Hexavalent Chromium (ug/l)	0.09	ND - 0.18	0.03 ug/l	Naturally-occurring element; used in making steel and other alloys; chromium-3 or -6 forms are used for chrome plating, dyes, and pigments, leather tanning and wood preservation.	
Total Chromium (ug/l)	0.12	ND - 1.4	0.2 ug/l	Naturally-occurring element; used in making steel and other alloys; chromium-3 or -6 forms are used for chrome plating, dyes, and pigments, leather tanning and wood preservation.	
1,4-Dioxane (ug/l)	0.5	ND - 2.1	0.07 ug/l	Cyclic aliphatic ether; used as a solvent or solvent stabilizer in manufacture and processing of paper, cotton, textile products, automotive coolant, cosmetics and shampoos.	
Molybdenum (ug/l)	5.28	2.7 - 7.4	1 ug/l	Naturally-occurring element found in ores and present in plants, animals and bacteria; commonly used form molybdenum trioxide used as a chemical reagent.	
Strontrium (ug/l)	594.2	430.0 - 890.0	0.3 ug/l	Naturally-occurring element; historically commercial uses of strontium has been in the faceplate glass of cathode-ray tube televisions to block x-ray emission.	
Vanadium (ug/l)	1.2	ND - 2.8	0.2 ug/l	Naturally-occurring elemental metal; used as vanadium pentoxide which as a chemical intermediate and a catalyst.	

CIUDAD DE PARAMOUNT

INFORME CONFIANZA DE CONSUMIDOR 2015

Desde 1991, las agencias proveedoras de recursos hidráulicos de California han emitido información sobre el agua que se provee al consumidor. Este informe es una copia del informe sobre la calidad del agua potable que le proveímos el año pasado. Incluimos detalles sobre el origen del agua que toma, cómo se analiza, que contiene, y cómo se compara con los límites estatales y federales. Nos esforzamos por mantenerle informado sobre la calidad de su agua, y proveerle un abastecimiento confiable y económico que cumpla con todos los requisitos.

¿De Dónde Proviene el Agua que Tomo?

Su agua de la llave proviene de 2 fuentes: de las aguas naturales (subterránea) y de aguas superficiales (de los ríos). Bombeamos aguas naturales de profundos pozos locales. También usamos agua superficial de la agencia Metropolitan Water District del Sur de California (MWD) importada del Río Colorado y del proyecto State Water Project del Norte de California. Estas dos fuentes de agua nos abastecen en las áreas de servicio que se muestran en el mapa adjunto. Este reporte informa sobre la calidad de nuestra agua subterránea y el abastecimiento del agua superficial del MWD.

¿Cómo Se Analiza Mi Agua Potable?

El agua que toma se analiza regularmente para asegurarnos de que no halla niveles altos de sustancias químicas, de radioactividad o de bacteria en el sistema de distribución y en las tomas de servicios. Estos análisis se llevan a cabo semanal, mensual, trimestral, y anualmente o con más frecuencia, dependiendo de la sustancia analizada. Bajo las leyes estatales y federales, se nos permite analizar algunas sustancias menos frecuentemente que los períodos anuales porque los resultados no cambian.

¿Cuáles Son Los Estándares del Agua Potable?

La Agencia de Protección Ambiental estadounidense (USEPA) limita la cantidad de ciertas sustancias permitidas en el agua del grifo. En California, la Junta de Control de Recursos Hídricos del Estado (State Board) regula la calidad del agua de beber siguiendo normas que sean al menos tan estrictas como las normas federales. Históricamente, los límites de California son más rigurosos que los Federales.

Hay dos tipos de límites conocidos como estándares. Los estándares primarios lo protegen de sustancias que potencialmente podrían afectar su salud. Las normas establecen los Niveles Contaminantes Máximos (MCL, en inglés) que se permite del contaminante primario o secundario en el agua de beber. Los abastecedores de agua deben asegurarse de que la calidad de esta cumpla con los Niveles Contaminantes Máximos (o MCLs, en inglés). No todas las sustancias tienen un Nivel Contaminante Máximo. El plomo y el cobre, por ejemplo, son regulados, por cierto nivel de acción. Si cualquier sustancia química sobrepasa el nivel de acción, se dará la necesidad de un proceso de tratamiento para rebajar los niveles en el agua de beber. Los abastecedores de agua deben cumplir con los Niveles Contaminantes Máximos para asegurar la calidad del agua.

Las Metas para la Salud Pública (MSP [o PHGs, en inglés]) son establecidas por la agencia estatal de California-EPA. Las PHGs proveen más información con respecto a la calidad del agua, y son similares a los reglamentos federales nombrados Metas para Los Niveles de Contaminante Maximos (MNCM [o MCLGs, en inglés]). Las PHGs y MCLGs son metas a nivel

recomendable. Las PHG y MCLG son ambas definidas como los niveles de contaminantes en el agua potable por debajo de los niveles donde no se esperan riesgos a la salud y no enforzables. Ambos niveles PHG y MCLG son concentraciones de una sustancia en las que no hay riesgos a la salud aún conocidos.

¿Cómo Interpreto Mi Informe de Calidad del Agua?

Aunque analizamos más de 100 sustancias, las normas nos requieren que reportemos solo aquellas que se encuentran en el agua. La primera columna en la tabla de la calidad de agua muestra la lista de las sustancias detectadas en el agua. La siguiente columna muestra la lista de la concentración promedio y el rango de concentraciones que se hallan encontrado en el agua que usted toma. En seguida están las listas de el MCL, el PHG y el MCLG, si estos son apropiados. La última columna describe las probables fuentes u origen de las sustancias detectadas en el agua potable.

Para revisar la calidad de su agua de beber, compare los valores por encima del promedio, mínimos y máximos y el Nivel Contaminante Máximo. Revise todos los químicos que se encuentran por encima del Nivel Contaminante Máximo. Si los químicos sobrepasan el Nivel Contaminante Máximo no significa que sea detrimental a la salud de inmediato. Más bien, se requiere que se realicen análisis más frecuentemente en el abastecimiento del agua por un corto período. Si los resultados muestran sobrepasar el MCL, el agua debe ser tratada para remover esa sustancia, o el abastecimiento de esta debe decomisionarse.

¿Por Qué Hay Tanta Publicidad Sobre La Calidad Del Agua Potable?

Las fuentes del agua potable (de ambas agua de la llave y agua embotellada) incluye ríos, lagos, arroyos, lagunas, embalses, manantiales, y pozos. Al pasar el agua por la superficie de los suelos o por la tierra, se disuelven minerales que ocurren al natural, y en algunas ocasiones, material radioactivo, al igual que pueden levantar sustancias generadas por la presencia de animales o por actividades humanas.

Entre los contaminantes que pueden existir en las fuentes de agua se incluyen:

- Contaminantes microbianos como los virus y la bacteria, los que pueden venir de las plantas de tratamiento de aguas negras, de los sistemas sépticos, de las operaciones de ganadería, y de la vida salvaje;
- Contaminantes inorgánicos, como las sales y los metales, los cuales pueden ocurrir naturalmente o como resultado del desagüe pluvial, industrial, o de alcantarillado, producción de gas natural y petróleo, minas y agricultura.
- Pesticidas y herbicidas, los cuales pueden venir de varias fuentes tales como la agricultura, del desagüe pluvial, y de usos residenciales;
- Contaminantes de otras sustancias químicas orgánicas, incluyendo químicos orgánicos volátiles y sintéticos que son productos de procesos industriales y de la producción de petróleo, y que pueden provenir de las estaciones de gasolina, desagües pluviales urbanos, y agricultura aplicación y de sistemas sépticos;

- Contaminantes radioactivos, los cuales pueden ocurrir naturalmente o que pueden ser resultados de las actividades de la producción de gas natural y minería.

A fin de asegurar que el agua de la llave es segura para beber, la Agencia de Protección Ambiental de Los Estados Unidos (USEPA) y el Tablero de Control de Recursos de Echar agua Estatal (Bordo Estatal) prescriben regulaciones que limitan la cantidad de ciertos contaminantes en el agua proporcionada por sistemas de agua públicas. Los reglamentos de Bordo Estatal también establecen límites para contaminantes en el agua embotellado que debe proporcionar la misma protección para la salud pública.

Toda el agua potable, incluyendo el agua embotellada, puede contener cantidades pequeñas de ciertos contaminantes. La presencia de contaminantes no necesariamente indica que haya algún riesgo de salud. Para más información acerca de contaminantes y riesgos a la salud favor de llamar a la USEPA encargada de proteger el agua potable al teléfono (1-800-426-4791). Usted puede obtener más información sobre el agua potable al conectarse al Internet en los siguientes domicilios:

- <http://water.epa.gov/drink/standards/hascience.cfm>
(página federal de la EPA)
- www.waterboards.ca.gov/drinking_water/programs/index.shtml (sitio Web estatal)

Si presente, los niveles elevados del plomo pueden causar el problema de salud serio, sobre todo para mujeres embarazadas y chiquitos. El plomo en el agua potable es principalmente de materiales y componentes asociados con líneas de servicios y a casafontanería. Ciudad de Paramount es responsable de proporcionar el agua potable de alta calidad, pero no puede controlar la variedad de materiales usados en la fontanería de componentes. Cuando su agua ha estado sentándose durante varias horas, usted puede minimizar el potencial para la exposición de plomo limpiando con agua su grifo durante 30 segundos a 2 minutos antes de usar el agua para beber o cocinarse. Si usted está preocupado por el plomo en su agua, usted puede desear hacer probar su agua. La información en el plomo en el agua potable, probando métodos, y pasos que usted puede tomar para minimizar la exposición está disponible de la Línea directa de Agua Potable Segura o en <http://www.epa.gov/safewater/lead>.

¿Debería Tomar Otras Precauciones?

Algunas personas pueden ser más vulnerables a los contaminantes en el agua potable que el público en general. Las personas que tienen problemas imunológicos, o sea esas personas que están en tratamiento por medio de quimioterapia cancerosa; personas que tienen órganos transplantados, o personas con SIDA o desórdenes imunológicos, personas de edad avanzada, y los bebés que son particularmente susceptibles a ciertas infecciones. Estas personas deben de consultar a sus proveedores de salud médica. Las guías de la USEPA/Centros de Control de Enfermedades aconsejan cómo disminuir los riesgos para prevenir la infección de Cryptosporidium y otros contaminantes microbiales están

disponibles por teléfono de la USEPA encargada de proteger el agua potable al teléfono (1-800-426-4791).

Valoración de su Abastecimiento de Agua

MWD terminó un gravamen de sus fuentes del proyecto del agua del río y del estado de Colorado en 2002. Las fuentes del río de Colorado se consideran las más vulnerables a la reconstrucción, salida urbana/de la precipitación excesiva, aumentando la urbanización en la línea divisoria de las aguas, y las aguas residuales. Las fuentes del proyecto del agua del estado se consideran las más vulnerables a salida, a fauna, a agricultura, a reconstrucción y a las aguas residuales urbanas/de la precipitación excesiva. Una copia del gravamen se puede obtener por MWD que entra en contacto con en (213) 217-6850.

La ciudad de Paramount condujo un gravamen de sus fuentes de la agua subterránea en 2003. Grillas fuentes del oundwater se consideran las más vulnerables al proceso/almacenaje, galjanoplastia de metal/el acabar /el fabricar, tintoreros, gasolineras del automóvil, tiendas de cuerpo del automóvil, talleres de reparaciones del automóvil, yardas de la chatarra/del desecho/del salvamento, y plásticos/productores del producto químico/del petróleo de los sintéticos. Una copia de la evaluación aprobada puede ser obtenida por ponerse en contacto con el Departamento de Trabajos Público Supremo en (562) 220-2020.

¿Cómo Puedo Participar en las Decisiones Sobre Asuntos Acerca del Agua Que Me Puedan Afectar ?

El público es agradable asistir a las reuniones de la Comisión de las obras públicas situadas en la ciudad pasillo, avenida de 16400 Colorado, Paramount, CA de Paramount 90723. Las reuniones se celebran en el 1st Jueves de cada mes en 6:00 P.M.

¿Cómo Me Pongo En Contacto Con Mi Agencia del Agua Si Tengo Preguntas Sobre La Calidad Del Agua?


Si usted tiene preguntas específicas en la calidad del echar agua del grifo, por favor póngase en contacto Sarah Ho, Asistente de Director de Obras Públicas en (562) 220-2020.

Algunas extremidades provechosas de la conservación del agua

- Arreglar los grifos que gotean en su hogar - excepto hasta 20 galones cada día por cada detenido de fugas
- Guardar entre 15 y 50 galones por cada vez que el lavado sólo cargas completas de ropa
- Ajuste sus regaderas de modo que el agua caiga en su césped / jardín, no la acera / calzada - excepto 500 galones por mes
- Utilice pajote orgánico alrededor de las plantas para reducir la evaporación - guardar cientos de galones por año
- Usan showerhead eficiente de agua. Ellos son baratos, fáciles para instalar, y pueden salvarle hasta 750 galones por mes.

Visítenos en www.paramountcity.com

CITY OF PARAMOUNT 2015 CONSUMER CONFIDENCE REPORT



Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hágale con alguien que lo entienda bien. Para obtener una copia en Español, llame a (562) 220-2020.

CITY OF PARAMOUNT
16400 COLORADO AVENUE
PARAMOUNT, CA 90723