

Paramount Water
Hexavalent Chromium Testing-UCMR Sites
(February/2018)

Sample Date	Average	Range	Minimum Reporting Level	Major Sources in Drinking Water
2/5/18	0.162	0.025 – 0.410	.03 ug/l	Naturally-occurring element; used in making steel and other alloys; chromium-3 or -6 forms are used for chrome plating, dyes, and pigments, leather tanning and wood preservation.